



**PURCHASING DIVISION  
ROOM 210 CITY HALL  
142 EAST MAIN STREET  
MERIDEN, CONNECTICUT 06450-8022**

**WILMA C. PETRO, CPPB, C.P.M.  
PURCHASING OFFICER**

**PHONE 203-630-4115  
FAX: 203-630-3852**

**NOTICE TO BIDDERS  
ADDENDUM #001**

TO THE BID FOR: B018-16 Benjamin Franklin Boiler Replacement

FOR: City of Meriden

BID DUE DATE: **May 30, 2018 at 2:00 PM**

Please acknowledge receipt of all addenda on the Proposal Pages.

**GENERAL**

1. Existing Chimney is 50'-0"(+/-).

**RFIs**

1. What size and how much piping will be required when reinsulating (with PVC color coded jacket) the existing piping in the mechanical room? Drawings do not reflect the existing lines, nor sizes.
  - a. Should we carry an allowance for this work?

**Answer:** The existing Chilled Water and domestic hot, cold and recirculating hot water piping insulation shall remain. Provide new insulation for the hot water supply and return pipes. All pipe insulation, new and existing, shall be covered with color coded PVC insulation. Cost of the insulation shall be included in the bid, no allowance.

2. Will the long weekend coming up will the bid be extended?

**Answer:** Bid will not be extended

3. Can regular 20amp, 120V commercial grade toggle switches and red emergency plates be used for the two EPO switches?

**Answer:** Yes, this is acceptable.

4. What is the voltage, amps and phase of the two existing HWH-1 and HWH-2 domestic Hot water Heaters?

**Answer:** Both are 120V, single phase.

5. What is the Manufacturer and Model of existing panel HPB circuit breakers?

**Answer:** We do not have this information at this time.

6. Will the new Carbon monoxide Detector be low voltage or line voltage?

**Answer:** Please refer to Note on Drawing E1.1; low voltage.

7. Who is the existing Fire Alarm Vendor?

**Answer:** The Fire Alarm is Siemens; contact is Mr. Bill Church: 860 883-3192.

8. Are there any spare circuit breaker space available in the existing panel HPB?

**Answer:** There is not enough spare space available, therefore, replace existing circuit breakers with new as indicated on drawings.

Wilma C. Petro, CPPB, C.P.M.  
Purchasing Officer

Dated: May 25, 2018

BEMIS ASSOCIATES, LLC

Consulting Engineers

B|A

101 Fenn Road  
Newington, CT 06111  
(860) 667-3233  
Fax: (860) 667-3579  
www.bemisassociates.com

NAME	FIRM	PHONE	E-MAIL
Robert DiNino	CT HVAC Inc	860-918-6224	rdinino@cthvact.com
Rich Miller	CT Boiler Repair	860 953 9117	rich_miller@ct-boiler.com
Michael Ruocco	SARRACCO	203-980-3039	MRUOCCO@SARRACCO.COM
JOHN MAULYCC	HHS MECHANICAL CONTRACTORS	860-643-3939	john@hhs-mech.com
David Keeney	Keeney Rigging	860 2805021	info@KeeneyRigging.com
JOAN PIETRO	A's Combustion Corp	203 223 3083	JOAN@A'COMBUSTION.COM



