



**PURCHASING DIVISION  
ROOM 210 CITY HALL  
142 EAST MAIN STREET  
MERIDEN, CONNECTICUT 06450-8022**

**RAWLE DUMMETT  
PURCHASING OFFICER**

**PHONE 203-630-4115**

**ADDENDUM #006**

**TO THE PROPOSAL FOR: B024-01 ARPA - Meriden Boys and Girls Club Renovations**

**FOR: City of Meriden**

**PROPOSAL DUE DATE: February 23, 2024 @ 1:30 PM**

**The purpose of Addendum is to provide additional information to bidders.**

**Question: Do you have any information on Test Cuts for the roof? ( what is the existing roof or Asbestos testing?)**

**Answer: Please see test cuts info below. No asbestos testing was done.**

**MAIN ROOF OVER GYM AREA**

**Sloped steel deck**

**2" polyiso mechanically attached**

**½" wood fiber mopped in asphalt**

**4 ply gravel surfaced BUR**

**SMALL ROOF OVER ENTRANCE LOBBY**

**Concrete deck**

**Coal tar pitch vapor barrier, or thick residue of material that was left when they re-roofed.**

**2" polyiso, not positive if mopped or mechanically anchored**

**½" wood fiber mopped**

**4 ply BUR**

**Please acknowledge receipt of all addenda in your Bid**

**Rawle Dummett  
Purchasing Officer  
Dated: February 14, 2024**