

## PURCHASING DIVISION ROOM 210 CITY HALL 142 EAST MAIN STREET MERIDEN, CONNECTICUT 06450-8022

## RAWLE DUMMETT PURCHASING OFFICER

PHONE 203-630-4115

## **ADDENDUM #003**

TO THE PROPOSAL FOR: B024-36 ARPA - Women's Locker Room Renovations

FOR: City of Meriden

PROPOSAL DUE DATE: February 22, 2024 @ 11:30 AM

The purpose of Addendum is to provide additional information to bidders.

Question: Please provide a floor to deck height?

Answer: Answer: From lower level floor to underside of deck above is 13'-6". There are mainly 12"

deep steel beams with bottom at 12'-6" above the floor.

Question: What is the brand name of the existing fire alarm system?

Answer: Answer: 1988 non-addressable autocall Panel

Question: Please provide a hardware spec? Plans only say match existing

Answer: The elevator recall panel is a Silent Knight Addressable-SK protocol. Contractors shall provide an exact upgrade.

**Question:** What detail do you have for locker resinous base? Are lockers on legs or on concrete slab? **Answer: There is no detail for the locker base. The lockers have their own support legs and simply sit on** 

the resinous floor

Please acknowledge receipt of all addenda in your Bid

Rawle Dummett
Purchasing Officer
Dated: February 14, 2024