



**PURCHASING DIVISION
ROOM 210 CITY HALL
142 EAST MAIN STREET
MERIDEN, CONNECTICUT 06450-8022**

**ADAM B TULIN, MPA
PURCHASING OFFICER**

PHONE 203-630-4115

NOTICE TO BIDDERS

ADDENDUM #003

TO THE BID FOR: B020-36 Boiler Replacement at 61 Pratt Street

FOR: City of Meriden

BID DUE DATE: June 23, 2020 at 11:00 AM

Please acknowledge receipt of all addenda on the Proposal Pages.

1. The specifications state that we must provide a new CO detector, and connect to local fire alarm circuit. Please provide contact information for the fire alarm vendor. **Current servicer of Fire Alarm System is Mule Security Systems (203)-238-7561.**
2. Mech. Demolition Note 7 states: Provide new emergency gas shutoff valve. There is no specification for this valve. **This is a manual valve located by the meter, not a solenoid valve**
3. Please confirm natural gas supply pressure from new gas meter to new gas fired equipment for regulators. **The information available to the City, indicates low pressure. The selected contractor will have to confirm with the gas company**
4. What is the purpose of ASCO contactor #91862031XC with 47L solid state control? What does this control? **This contactor is used to shut-down multiple appliances in case of emergency**
5. What is the contract period for completion in calendar days? **Assume that the boiler must be installed by the beginning of the heating season (end of September) while the domestic water heater has to be installed ASAP.**

Please check the City of Meriden and the State of Connecticut Department of Administrative Services Website often for any updates. Due to the COVID19 virus, schedules may need to be changed because of the uncertainty of the current situation.

Adam B Tulin, MPA
Purchasing Officer
Dated: June 18, 2020