



**PURCHASING DIVISION
ROOM 210 CITY HALL
142 EAST MAIN STREET
MERIDEN, CONNECTICUT 06450-8022**

**RAWLE DUMMETT
PURCHASING OFFICER**

PHONE 203-630-4115

ADDENDUM #003

TO THE BID FOR: B024-33 –Center Street /Bridge State Project No. 79-212 Center St Bridge No. 04185

FOR: City of Meriden

BID DUE DATE: January 24, 2024 @ 11 AM

The purpose of this Addendum is to provide additional information to bidders.

Question: Is a redesign of the culvert allowed on this project or do we need to follow the design shown on the Contract Plans?

Answer: Redesign of the culvert is allowed but the hydraulic opening must match what is shown on the plans. Additionally, the designer will need to provide load ratings along with their redesign which would be subject to review and approval by the engineer, city and state.
Please acknowledge receipt of all addenda in your Bid Submission.

Bid Delivery - Proposals may be dropped off prior to January 24, 2024, either in person or by courier service. At this time the City does not have the infrastructure to accept electronic proposals and therefore bids will only be accepted as directed in the Bid documents.

Rawle Dummett
Purchasing Officer
Dated: January 12, 2024