



**PURCHASING DEPARTMENT
ROOM 210 CITY HALL
142 EAST MAIN STREET
MERIDEN, CONNECTICUT 06450-8022**

**ADAM B TULIN, MPA
PURCHASING OFFICER**

PHONE (203) 630-4115

**NOTICE TO BIDDERS
ADDENDUM #001**

TO THE BID FOR: B020-20 Miller St Parking Lot

FOR: City of Meriden

Please acknowledge receipt of all addenda on the Proposal Pages.

Pre-Bid Meeting Sign in Sheet – Page 2

Q1: The specs call for some new lights in the parking lot. Are the poles to be supplied by the City or the Vendor?

A1: The poles are to be supplied by the vendor. The vendor must supply the City's standardized pole.

Q2: Does the City have a preference for Pre-Cast Bases or Poured in Place bases for the light poles?

A2: The City has no preference. Bidders shall reflect in their unit pricing what they plan to use.

Q3: Does the City have a preference for Pre-Cast or Poured in Place for curbing?

A3: The City has no preference. Bidders shall reflect in their unit pricing what they plan to use.

Q4: Light poles typically have a long lead time from order to delivery. This may be an issue with the 60 day contract schedule.

A4: The poles specified in the documents are fairly common poles. If the contractor finds that there is a long lead time they are to notify the City and provide a written commitment from the manufacturer/distributor that states the delivery date.

Adam B Tulin
Purchasing Officer
Dated: March 17, 2020

